

B. Re-use of materials

1. Unless otherwise specified, temporary landscape fence components will remain the property of the contractor and may be re-used as desired.
2. Fence fabric and posts to be re-used must be clean, in good condition and without damage, including, but not limited to: tears, bends, loss of vinyl coating or paint, etc.
3. CPD project manager must approve the condition of all fence materials to be re-used.

2.02 Standard Landscape Protection Fencing

A. Wire mesh system

1. Fence fabric
  - a. Fence fabric shall be 48" tall welded wire mesh with 4" x 2" mesh openings, wire to be black vinyl coated steel, 12 gauge (actual wire gauge is 14; 12 gauge is achieved after vinyl coating)
  - b. Fence fabric shall be product number C120S481B, as manufactured by C. E. Shepherd Co. Inc., P.O. Box 9445, Houston Texas, 77261-9445; (800) 324-6733 or approved equal.
2. Fence posts
  - a. Fence posts shall be 13-gauge steel "U" channel, 1 $\frac{3}{4}$ " wide, 6 ft long.
  - b. Fence posts shall have black painted finish or approved equal.

B. Plastic mesh system

1. Fence fabric
  - a. Fence fabric shall be 48" tall polyethylene plastic, dark green in color, with 1 $\frac{1}{2}$ " x 1 $\frac{1}{2}$ " square or diamond-shaped openings.
  - b. Please note: Orange or other "safety" colored fence fabric is NOT acceptable.
2. Fence posts
  - a. Fence posts shall be 13-gauge steel "U" channel, 1 $\frac{3}{4}$ " wide, 6 ft long.
  - b. Fence posts shall have black or dark green painted finish or approved equal.

2.03 Rabbit Exclusion Fencing

A. Metal hardware cloth system

1. Fence fabric
 

Fence fabric shall be metal hardware cloth with 1/4" to 1/2" square openings, 20" to 24" in height.
2. Fence posts
 

Fence posts shall be 1" x 1" wooden stakes, or 3/8" or 1/2" round metal stakes, or other approved stake material, 30" to 36" in length.

B. Corrugated plastic tubing system